

For: Don Roberts, Roberts Legacy LLC  
Static Water Levels on Irrigation Wells.

March 19<sup>th</sup>, 2024

Buckhorn Flat West Farm:

- #1- Static level 70'10" 300HP Goulds Pump
- #2- Static level 70' 100HP Western Landroller Pump
- #3- Static level 59' 100HP Goulds Pump

East Buckhorn Flat Lone Tree Farm:

- #1- Static level 123'4" 300HP Johnston Pump
- #2- Static level 132' 150HP Johnston Pump
- #3- Static level 92' 300HP Floway Pump

South East Buckhorn Flat Old Roberts Farm:

- #1- Static level 166'7" 200HP FM Pump
- #2- Static level 164' 250HP Johnston Pump
- #3- Static level 169'10" 300HP BJ Pump

Paragonah East Evans Place:

- #1- Static level 142'8" 125HP Goulds Pump

Parowan Church Farm, North:

- #1- Static level 172'4" 100HP Vertiline Pump
- #2- Static level 148' 150HP Johnston Pump

Parowan Church Farm, South:

- #1- Static level 146'6" 75HP BJ Pump (drop in level likely due to well issues)
- #2- Static level 130'6" 125HP Layne Pump
- #3- Static level 100'6" 300HP Goulds Pump
- #4- Static level 101'4" 200HP Layne Pump
- #5- Static level 104'" 300HP Western Landroller Pump
- #6- Static level 157'8" 75HP BJ Pump (drop in level likely due to well issues)

Evens Farm:

- #1- Static level 163'8" 300HP Johnston Pump
- #2- Static level ? Line hangs up at 134' and will go no futher

I certify that these static water level readings were performed by me on 3/19/2024 with a Heron water level indicator and are accurate and true.

Darrin Rhodes

Rhodes Pumps ll LLC

Fillmore, Utah 84631

1-435-979-0671