



State of Utah  
DEPARTMENT OF NATURAL RESOURCES  
DIVISION OF WATER RIGHTS

Michael O. Leavitt  
Governor  
Ted Stewart  
Executive Director  
Robert L. Morgan  
State Engineer

Eastern Area  
State/County Building  
152 East 100 North  
Vernal, Utah 84078-2110  
801-781-0770 x 327

May 24, 1993

John Wilde  
McKinnon, WY 82938

RE: Beaver Creek Distribution System  
Control Structures & Measuring Devices

Dear Mr. Wilde:

It has been brought to our attention that the bottom of the parshall flume on the Midway ditch has rusted out and is in need of repair; and at the Baldy Springs diversion, a flume is needed in the canal below the return flow diversion.

Section 73-5-4 of the Utah Code Annotated, 1953 as amended states in part:

"Every person using water in this state shall construct or install and maintain a substantial headgate, cap, valve or other controlling works, weir, flume and measuring device at each point where water is diverted or turned out, for the purpose of regulating and measuring the quantity of water that may be used."

Therefore, you are hereby notified that you need to repair and/or install such devices and structures as will adequately control and measure the water.

If there are special circumstances or if you have any questions, please contact me at the Vernal Office at 781-5327 or Lee Sim, Directing Engineer for Adjudication/Distribution at 538-7380.

Sincerely,

A handwritten signature in black ink, appearing to read 'Robert W. Leake'.

Robert W. Leake, P.E.  
Regional Engineer

RWL:bmw

pc: Lee Sim  
Jim Hickey

