



JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

State of Utah

DEPARTMENT OF NATURAL RESOURCES

Division of Water Rights

MICHAEL R. STYLER
Executive Director

JERRY D. OLDS
State Engineer/Division Director

Sandy Ranch
C/O Steve Dalton
PO BOX 149
Teasdale, UT 84773

October 16, 2006

RE: SEAA 1143: Pleasant Creek – Lower Bowns Measuring Device Requirement

Water User,

On May 22nd, 2006, representatives from the State Engineers' Division of Water Rights sent you the referenced notice for a measuring device requirement to measure water diverted to the Lower Bowns Reservoir at the Lower Bowns – Pleasant Creek Diversion Structure located on the east flank of Boulder Mountain.

Subsequently on October 11, 2006, representatives from the State Engineers' Division of Water Rights inspected the Lower Bowns – Pleasant Creek Diversion Structure on the east flank of Boulder Mountain, and observed weir plates installed on the discharge side of the structure that leads to Lower Bowns Reservoir. In addition, gravel in the diversion structure has been removed. Therefore a suitable measuring device has been installed as required and the subject agency action can be formally concluded. Your efforts to comply with the order are commended and appreciated.

Please contact the Lower Fremont Water Commissioner, Becky Taft at (435) 425-3206, for any follow up requirements. Please be aware that maintenance of the installed structure remains your responsibility in conjunction with other water users. You should consult regularly with the Water Commissioner or the Division of Water Rights to assure proper maintenance and continued functioning of the measuring device is completed to our satisfaction.

Thank you for your cooperation in attending to this matter in a timely fashion. If you have any questions concerning this notice, please contact Mike Silva, Distribution Engineer by phone at 801-538-7430 or by e-mail at MikeSilva@Utah.Gov or Kirk Forbush, Regional Engineer, by phone at 435 896-4429 or by e-mail at KirkForbush@utah.gov.

Sincerely,

Mike Silva

Mike Silva.

Distribution Engineer

cc: Distribution File File SEAA 1143
Kirk Forbush, Regional Engineer
Becky Taft, Water Commissioner PO BOX 154, Bicknell, UT 84715

SCANNED