



GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

State of Utah

DEPARTMENT OF NATURAL RESOURCES

MICHAEL R. STYLER
Executive Director

Division of Water Rights

KENT L. JONES
State Engineer/Division Director

October 15, 2009

North Slaterville Irrigation Company
c/o Douglas Eggleston
2434 West Pioneer Rd
Ogden, UT 84404

RE: **Ogden River Distribution System**, SEAA1298, Account 101470, WR No. 35-7014.

Dear Mr. Eggleston:

This letter is to report to you the findings of our inspection of the work outlined in SEAA 1298 issued to North Slaterville Irrigation Company on January 15, 2009. Our staff and the commissioner inspected your weir with the commissioner in July. The following two items require attention and correction in order to be in substantial compliance with SEAA 1298:

- The weir crest needs to be level and straight
- A new staff gage must be properly installed

We measured a 0.03 ft difference in elevation between the center of the weir crest and the north (right) side of the weir. We could not measure the south (left) side of the weir crest due to dense vegetation that restricted our access. Also, there is a need for a conventional staff gage to readily measure the water height above the weir crest. The steel gage marker placed on the bridge abutment appears to be at an acceptable gage location, but is not sufficient. The zero mark on the new staff gage should be at the same elevation as the entire weir crest in order to measure the water correctly.

We recommend these two items be completed without delay. Properly completing these two items should satisfy the SEAA 1298 requirements if they are completed before March 31, 2010. We appreciate your efforts to help the Ogden River Distribution System operate smoothly. If you have questions regarding the uncompleted SEAA 1298 requirements, please call me at (801) 538-7469.

Sincerely,

Ben L. Anderson, P.E.
Water Rights Distribution Engineer

cc: Ross Hansen, Regional Engineer
Jim Wells, Ogden River Water Commissioner
Neil Sanders, Secretary of North Slaterville Irr Co.

SCANNED



U.S. Postal Service™ Delivery Confirmation™ Receipt

Postage and Delivery Confirmation fees must be paid before mailing.

Article Sent To: (to be completed by mailer)

North Statesville Inc.

(Please Print Clearly)

DELIVERY CONFIRMATION NUMBER:
0308 1400 0001 9804 1429

Postmark
Here

POSTAL CUSTOMER:

Keep this receipt. For Inquiries:
Access internet web site at
www.usps.com[®]
or call 1-800-222-1611

CHECK ONE (POSTAL USE ONLY)

- Priority Mail™ Service
- First-Class Mail® parcel
- Package Service® parcel