

Lee Sim



RECEIVED


JUL 15 1996

WATER RIGHTS
SALT LAKE

memorandum

July 10, 1996

To: Bob Cowdell - SLO

From: Walt Donaldson - NER 

Subject: Correction Need of Measuring Flume - Crouse Reservoir

Attached for your review is a letter from Bob Leake, Area Engineer, requesting correction of the measuring flume at Crouse Reservoir. Evidently the flume was incorrectly installed, and currently delivers false readings as water is released from the dam. He recommends either reseating of the flume, or deepening the channel several hundred feet below the lip of the flume.

Because this is an important flume recording water delivery to Colorado, it is imperative that the flume situation be corrected before early Spring, 1997. Would you please contact the appropriate individuals, and let's have the contractor who reconstructed the dam return and correct the problem? Also, when the correction work is being done on the flume, NER would like the area engineer to conduct an on site inspection for validation.

Your assistance with this correction issue is appreciated.

pc: Bob Leake - Area Engineer (Vernal)
Lee Sim - Water Rights (SLO)
Mike McCarrell - Pot Creek Water Commissioner
Rick Larson - NER Habitat Manager
Chad Crosby - NER Aquatic Manager

Attachment (1)