M 3001-1-5M-3-13 THE ARROW PRESS, 66 W. SECOND SOUTH, SALT LAKE

UTAH POWER & LIGHT COMPANY

DEPARTMENT OF

GENERATION AND TRANSMISSION

Daily Load Sheet

Date JUL 5 [illegible] P. M.

Time	Grace	Logan	Hyrum	Wheelon	Riverdale	Lower Mill Cr.	Upper Mill Cr.	Snake Creek	Murdock	Alpine	Lower Am. Fork	Upper Am. Fork	Battle Creek	Olmstead	Santq.	[illegible]		TOTAL
12:30	6500	1700	2000	2100	500	800		110	200	1000	70		370	3600	520	76		19546
1:00	6500	1700	2000	2100	500	800		110	200	1000	70		370	3200	520	76		19148
1:30	7000	1700	2000	2100	500	800		110	–	1000	67		370	3860	500	75		20182
2:00	7000	1700	2000	2100	500	1000		110	–	1000	67		370	3720	490	76		20133
2:30	7500	1700	2000	2700	500	800		110	100	1000	77		370	3760	470	76		21213
3:00	8000	1700	2000	2700	500	800		110	100	1000	77		370	3560	440	78		21185
3:30	7500	1700	2000	2900	500	800		110	100	1000	57		370	3080	440	78		20685
4:00	7000	1700	2000	2900	500	600		110	–	1000	57		370	2920	440	78		19725
4:30	7000	1700	2000	2300	500	800		110	–	1000	67		370	3600	440	78		19965
5:00	7500	1700	2000	2300	500	600		110	100	1000	67		370	3500	440	78		20265
5:30	7500	1700	2000	2100	500	400		100	–	1000	87		370	3840	420	80		20097
6:00	7500	1700	2000	2100	500	600		100	100	1000	87		370	3760	420	90		20307
6:30	7500	1700	2000	2100	1500	400		100	200	1000	85		370	2320	420	90		19765
7:00	6000	1700	2000	2100	1500	600		100	200	1000	85		370	2640	440	90		18205
7:30	6500	1700	2000	2100	1500	400		110	200	1000	85		370	3640	430	85		20119
8:00	5500	1700	2000	2100	1500	600		110	200	1000	85		370	2580	440	105		18290
8:30	7000	1700	2000	2000	1500	800		110	100	1000	85		370	3020	440	125		20300
9:00	6500	1700	2000	2100	1500	800		110	100	1000	159		370	3160	460	150		20013
9:30	6500	1700	2000	2200	1500	800		110	200	1000	197		370	3420	460	150		20611
10:00	6000	1700	2000	2200	1500	800		110	200	1000	197		370	3540	460	160		20217
10:30	6500	1700	2000	2300	1500	800		110	100	500	142		370	3640	460	170		20292
11:00	6500	1700	2000	2300	1500	800		110	100	500	142		370	4000	460	100		20632
11:30	8000	1700	2000	2000	1500	600		110	200	500	99		370	3500	460	90		21679
12:00	7500	1700	2000	2000	1500	600		110	200		99		370	3040	460	76		19705
Average Load	6441 2/3	1708	2012	1998	520	716 2/3		110	88	612	90		338.33		478 2/3	81		18609
Peak Load	8500	1700	2000	2900	1500	1000		110	200	1000	210		370	4400	500	150	58	22555
Minimum Load	4000	1700	2000	1100	500	600		100	100	500	57		290		490			14006
Load Factor																		83.5
K.W. Hours	154600	40982	48300	47900	12500	17200		2640	2100	14690	2167	575	8120	8500	11490	1960	300	446904
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	