301-1-5M-3-13 THE ARROW PRESS, 66 W. SECOND SOUTH, SALT LAKE

UTAH POWER & LIGHT COMPANY

DEPARTMENT OF

GENERATION AND TRANSMISSION

Daily Load Sheet in Kilowatts

Date AUG 7 - 1913 A. M.

Time	Grace	Logan	Hyrum	Wheelon	Riverdale	Lower Mill Cr.	Upper Mill Cr.	Snake Creek	Murdock	Alpine	Lower Am. Fork	Upper Am. Fork	Battle Creek	Olmstead	Santq.			TOTAL
12:30	7000	1600	2000	1500	2400	900	320	540	0	600	107	450	410	350	370	70		22127
1:00	7500	1600	1500	1400	2400	800	370	540	150	600	107		410	390	360	70		21132
1:30	7500	1600	1500	1400	2350	800	370	540	150	600	107		410	360	360	70		21462
2:00	7000	1600	1500	1500	2350	800	370	530	50	600	107		410	350	370	68		20930
2:30	7000	1600	1500	1500	2350	800	370	530	50	600	107		410	390	370	68		20440
3:00	6500	1600	1500	1500	2350	900	370	540	0	600	110		410	310	400	66		19931
3:30	6500	1600	1500	1500	2350	900	370	540	0	600	110		410	370	400	66		20551
4:00	7000	1600	1500	1500	2350	800	370	540	0	600	97		410	360	400	66		20548
4:30	6500	1600	1500	1500	2350	800	370	200	50	600	97		410	370	370	66		19696
5:00	6500	1600	1500	1400	2300	800	370	530	0	600	105		410	380	370	70		20000
5:30	6500	1600	1500	1400	2300	900	370	120	0	600	105		410	390	370	66		20090
6:00	6500	1600	1500	1400	50	800	370	130	50	600	107		410	380	370	70		17792
6:30	10000	1600	2500	1400	100	800	370	130	50	600	107		410	380	370	75		22277
7:00	9000	1600	2500	1600	700	900	320	180	0	600	125		410	380	370	126		21251
7:30	9000	1600	2000	1600	700	900	320	180	0	600	125		410	380	370	102		22347
8:00	10000	1600	2000	1600	500	800	320	510	140	600	120	325	410	470	370	102		24397
8:30	10000	1600	2000	1600	400	900	320	510	140	600	120	325	410	340	370	160		22926
9:00	10000	1600	2000	1500	600	800	320	860	360	600	134	375	410	340	370	162		23695
9:30	9500	1600	2000	1500	2400	800	320	860	360	600	134	375	410	3660	370	112		25201
10:00	8500	1600	1500	1500	2300	1000	320	850	360	600	204	375	410	3620	380	118		23537
10:30	9500	1600	1500	1500	2300	1000	320	850	360	600	204	375	410	3640	380	135		25074
11:00	8500	1600	1500	1500	2350	900	320	830	360	600	165	600	410	3260	380	128		23423
11:30	8500	1600	1500	1500	2350	900	320	830	360	600	165	600	410	3200	380	150		23365
12:00	7500	1600	1500	1500	2350	900	320	850	350	600	165	600	410	3660	380	146		23821
Average Load																		
Peak Load																		
Minimum Load																		
Load Factor																		
K. W. Hours																		

001-1-5M-3-13 THE ARROW PRESS, 66 W. SECOND SOUTH, SALT LAKE

UTAH POWER & LIGHT COMPANY

DEPARTMENT OF

GENERATION AND TRANSMISSION

Daily Load Sheet in Kilowatts

Date AUG 7 - 1913 P. M.

Time	Grace	Logan	Hyrum	Wheelon	Riverdale	Lower Mill Cr.	Upper Mill Cr.	Snake Creek	Murdock	Alpine	Lower Am. Fork	Upper Am. Fork	Battle Creek	Olmstead	Santq.	[illegible]	[illegible]	TOTAL
12:30	6500	1600	1500	1500	2350	900	320	850	350	600	165	600	415	3640	350	138		20308
1:00	7500	1600	1500	1500	2350	800	320	880	340	600	135	575	415	4060	350	132		23067
1:30	9500	1600	1500	1500	2350	800	320	860	340	500	135	575	415	3760	350	126		24661
2:00	9000	1600	1500	1400	2350	900	320	850	340	500	165	575	415	3440	320	150		23975
2:30	9000	1600	1500	1400	2350	900	320	850	340	400	165	575	415	4060	300	132		24407
3:00	9000	1600	1500	1500	2350	900	320	860	340	400	135	600	415	3700	300	152		24162
3:30	9000	1600	1500	1500	2350	900	320	860	340	400	135	600	415	3700	300	152		24162
4:00	8000	1600	1500	1400	2350	900	320	850	340	400	157	600	415	3540	300	154		23154
4:30	8000	1600	1500	1400	2350	900	320	860	340	400	157	600	415	3440	350	150		22802
5:00	6000	1600	1500	1400	2350	900	320	850	350	400	149	600	415	3760	350	136		21312
5:30	6500	1600	1500	1400	2350	900	320	850	350	400	149	600	415	4020	400	130		22154
6:00	6500	1600	1500	1400	2350	900	320	840	350	400	122	575	415	3820	400	120		21502
6:30	5500	1600	1500	1400	2350	900	310	590	450	400	122	575	415	3200	400	126	58	20436
7:00	5500	1600	1500	1400	2350	900	310	890	440	400	144	600	415	3100	440	126	58	21043
7:30	6500	1600	1500	1400	2350	900	310	890	440	400	144	600	415	3900	400	140	58	22301
8:00	7500	1600	1500	1300	2350	900	310	850	450	400	132	575	415	4100	350	184	58	23074
8:30	7500	1600	1500	1300	2350	900	310	850	450	400	132	575	415	3400	350	150	58	22320
9:00	7500	1600	1500	1500	2300	900	310	870	370	400	157	600	440	3400	350	200	58	22460
9:30	7500	1600	1500	1500	2300	900	310	870	370	400	157	600	440	3500	350	140	58	22535
10:00	7000	1600	1500	1300	2300	900	310	870	350	400	157	600	440	3660	360	172	58	21957
10:30	7000	1600	1500	1300	2300	900	310	870	350	400	157	600	440	3500	360	100	58	21315
11:00	7000	1600	1500	1400	2300	900	310	890	340	400	137	575	440	4100	300	85	58	22555
11:30	7000	1600	1500	1400	2300	900	310	870	340	600	137	575	440	3400	300	76		22068
12:00	6500	1600	1500	1300	2300	900	310	850	350	600	107	500	440	3660	300	72		21322
Average Load	7962	1601	1600	1455	2345	875	317	865	365	496	137	463	416	3641	356	110	58	22394
Peak Load	10000	1600	2500	1700	2400	1600	320	890	450	600	215	600	440	4700	400	200	58	25201
Minimum Load	5500	1600	1500	1300	50	800	310	120	0	400	97	0	400	2820		66		17722
Load Factor														.77				.885
K.W. Hours	159450	38420	38400	33500	14400	21000	7600	16920	8350	11760	7350	9650	10000	87380	8340	46800	1392	537455