ENTRY DATE 2/3/93

000024

ATTACHMENT 1
TABLE 1

entered

PRIVATE WELL # 1 WATER QUALITY RESULTS
OWNER: COPPERTON CITY

UTAH STATE PRIMARY DRINKING WATER STANDARDS

PARAMETER	CONCENTRATION (MG/1)	WELL # 1 10/14/92
ARSENIC	0.05	0.008
BARIUM	1	0.197
CADMIUM	0.01	<.001
CHROMIUM	0.05	0.007
LEAD	0.05	<.001
MERCURY	0.002	0.0003
NITRATE (AS N)	10	1.1
SELENIUM	0.01	0.006
SILVER	0.05	<.001
SODIUM	NONE	20
SULFATE	1000	24
TOTAL DISSOLVED SOLIDS	2000	644

UTAH STATE SECONDARY DRINKING WATER STATNDARDS

PARAMETER	CONCENTRATION (MG/1)	WELL # 1 10/14/92
CHLORIDE	250	139
COPPER	1	0.004
IRON	0.3	0.09
MANGANESE	0.05	0.003
ZINC	5	<.005
PH	6.5-8.5	7.64

COLIFORM (TOTAL)	2	NA
COLIFORM (FECAL)	2	NA

ENTRY DATE 2/3/93

000031

ATTACHMENT 1
TABLE 2

entered

PRIVATE WELL # 2 WATER QUALITY RESULTS
OWNER: COPPERTON CITY

UTAH STATE PRIMARY DRINKING WATER STANDARDS

PARAMETER	CONCENTRATION (MG/1)	WELL # 2 7/22/92
ARSENIC	0.05	0.007
BARIUM	1	0.111
CADMIUM	0.01	<.0005
CHROMIUM	0.05	0.005
LEAD	0.05	0.002
MERCURY	0.002	<.0001
NITRATE (AS N)	10	<.02
SELENIUM	0.01	0.003
SILVER	0.05	<.001
SODIUM	NONE	20
SULFATE	1000	20
TOTAL DISSOLVED SOLIDS	2000	598

UTAH STATE SECONDARY DRINKING WATER STANDARDS

PARAMETER	CONCENTRATION (MG/1)	WELL # 2 7/22/92
CHORIDE	250	151
COPPER	1	0.002
IRON	0.3	0.12
MANGANESE	0.05	0.003
ZINC	5	0.027
PH	6.5-8.5	7.2

COLIFORM (TOTAL)	2	NA