

FORD ANALYTICAL LABORATORIES

DATE: 03/11/94 CERTIFICATE OF ANALYSIS

ARROW PACIFIC
 PLASTICS
 44 E. 8TH AVE.
 MIDVALE, UT 84047

94-020220

57-7909

SAMPLE: WELL WATER SAMPLE COLLECTED 2-24-94, 9:25 A.M. BY C.F.
 RECEIVED 2-24-94 FOR ANALYSIS.
 P.O. A-02988

	Results	Method Detection Limit
Calcium Ca mg/l EPA 200.7	30.4 ✓	.100
Chloride Cl mg/l EPA 325.3	40 ✓	2.0
Cond. umhos/cm EPA 120.1	416 ✓	.1
Iron Fe mg/l EPA 200.7	.019 ✓	.010
Manganese Mn mg/l EPA 200.7	ND ✓	.010
Nitrate NO3-N mg/l EPA 300	.87 ✓	.01
Sodium Na mg/l EPA 200.7	36 ✓	.500
Sulfate SO4 mg/l EPA 375.4	41 ✓	5
Tot.Dis.Solids mg/l EPA 160.1	226 ✓	10.0
pH Units EPA 150.1	7.4 ✓	
Temp. deg C at Receipt	19	
pH at Receipt - Satisfactory		

Joel Workman
 FORD ANALYTICAL LABORATORIES

* ND - INDICATES NONE DETECTED *

** < - INDICATES THE SMALLEST QUANTITY DETECTABLE DUE TO REQUIRED DILUTION **
 Cl, SO4, and Metal Analysis performed by Chemtech.

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.