(Robert McComb -
a-12431 -)

March 16, 1984 -

Field exam of Fields well woodland - inspected last circulation material placed in well - took samples - took pictures 300 bags of material - left card with note to contact office - Dale said 100 bags of material used Ranch foreman - said Robinson will be back Mon-Tues next week to try to clean out the well. Fred Dillerow will make contact set up meeting - Check with NWWA on material used -

Field exam of Epperson Well & Vincent Well: 3/20/84: EDF, JB Pane C. exam of wells - Vincent static level measured at 62.5' Epperson well not readily accessable. Vincent water - slight discoloration - Water from last week from Epperson well - considerable clay & suspended solids - very cloudy - today however - Epp. water is very clear with no apparent residue - some air entrained -