



GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

State of Utah

DEPARTMENT OF NATURAL RESOURCES

MICHAEL R. STYLER
Executive Director

Division of Water Rights

KENT L. JONES
State Engineer/Division Director

April 23, 2015

State Stone Corporation Inc.
Keith Mackay
4640 S 300 W
Murray, UT 84107

Dear Keith,

As we were making our startup inspection rounds for the Lower Fremont River, we noticed the screen is blank and no longer activates for your meter reading that measures water service to your operations from the Garkane Canal. Most likely the meter needs a battery replacement to function.

I contacted the manufactures representative about this and provided them with your meter info. They returned a quote which is attached. I would encourage you to contact them directly to get the special battery needed. If you need help installing it, either myself or Randy Bradbury can most likely get that done. Please contact me after you receive the battery. For future reference, meter information is below:

SEAMETRICS METER FT 415 M, Serial number: 02001946
Battery needed is a 100373, Lithium Battery, 3.6V, 8.5Ah, C size for FT415 Meter Mount

There was a similar meter at another location, also having problems which are other items on the quote, I have crossed out. These items related to the other meter. (You don't need these items).

The measurement requirement is one of the basic tenets of state water law and that responsibility is on the water users to have functional and accurate measuring devices as part of their diversions. I look forward to getting your meter functional. Since we have already started diversions, I request this be done as soon as possible. If a functioning meter has not been completed in a timely manner, (next 30 days), an enforcement order will be forthcoming. I would rather not go that route, since you have been good to work with in the past.

If you have any questions or comments please contact me at 801 538-7430 or by email at MikeSilva@utah.gov

Sincerely,

Mike Silva
Distribution Engineer

Encl: Quote attached from innovative Power Systems Inc- Denver

cc: Southern Regional office- Richfield
Randy Bradbury, Water Commissioner



Innovative Power Systems, Inc

7003 East 47th Ave
 Unit A-1200
 Denver, CO 80216

QUOTATION

Quote Number: 3018
 Quote Date: Apr 21, 2015
 Page: 1

Voice: 877-742-5477
 Fax: 866-590-6644

CONTACT: STEPHENNE CRAWFORD

Quoted To:

Customer ID	Good Thru	Payment Terms	Sales Rep
MISC	5/21/15	Prepaid	SJC

Quantity	Item	Description	Unit Price	Amount
1.00	100373	Battery, Lithium, 3.6V, 8.5Ah, C Size for FT415 meter/wall mount Indicators	56.00	56.00
<i>STATE STONE</i>				
1.00	IP210B-04	Adj Depth Insertion Paddlewheel Meter, Brass, 12"-40"	585.00	585.00
1.00	FT415W	Flow Meter Indicator, Wall Mount, Battery-Powered, 1000's of gallons totalizer	496.00	496.00
<p>FREIGHT will be added to this when shipped. Lead time is 2 weeks as we do not stock the "paddlewheel" style meters. Thank you. Stephenne</p>				
Subtotal				1,137.00
Freight				
TOTAL				1,137.00