



Norman H. Bangertter
Governor
Dee C. Hansen
Executive Director
Robert L. Morgan
State Engineer

State of Utah

DEPARTMENT OF NATURAL RESOURCES
DIVISION OF WATER RIGHTS

1636 West North Temple, Suite 220
Salt Lake City, Utah 84116-3156
801-538-7240

March 1, 1990

Mr. King Morris, Secretary
Aberdare Bench Canal Co.
Greenville, UT 84731

Dear Mr. Morris:

Re: Beaver River Dist. Sys.
Account 03-154

Mr. Gerald Stoker the Division of Water Rights Area Engineer for Southern Utah has informed us that there is not a functioning measuring device on the Aberdare Canal.

Section 73-5-4 of the Utah Code Annotated, 1953, as amended states in part:

"Every person using water in this State shall construct or install and maintain a substantial head-gate, cap, valve or other controlling works, weir flume and measuring device at each point where water is diverted or turned out, for the purpose of regulating and measuring the quantity of water that may be used."

Therefore, you are hereby ordered to install a measuring device prior to beginning of irrigation in 1990. The installation of the measuring device must be inspected by Mr. Stoker or Mr. Lee Strong the River Commissioner.


If irrigation is attempted in 1990 without a functional measuring device, agency action will be commenced to prevent your use of water until the meters are repaired or replaced.

Measuring devices are extremely important to the proper regulation of water use in your distribution system and we urge you to have one installed as soon as possible.

Aberdare Bench Canal Co.
continued - Page 2-

If you have any questions concerning this order, please contact Gerald Stoker, Area Engineer at 586-4231 or Lee H. Sim, Directing Engineer at 538-7380.

Sincerely,



Robert L. Morgan, P. E.
State Engineer
Division of Water Rights
1636 West North Temple
Salt Lake City, UT 84116

RLM:LHS:bd

cc: Gerald Stoker, Area Engineer
Lee Strong, River Commissioner
Brent Jones, Committee Chairman