

For: Don Roberts, Roberts Legacy LLC
Static Water Levels on Irrigation Wells.

April 13th 2023

Buckhorn Flat West Farm:

- #1- Static level 70'5" 300HP Goulds Pump
- #2- Static level 68'10" 100HP Western Landroller Pump
- #3- Static level 59'8" 100HP Goulds Pump

East Buckhorn Flat Lone Tree Farm:

- #1- Static level 119'6" 300HP Johnston Pump
- #2- Static level 127'8" 250HP Johnston Pump
- #3- Static level 91'4" 300HP Floway Pump

South East Buckhorn Flat Old Roberts Farm:

- #1- Static level 161'4" 200HP FM Pump
- #2- Static level 166' 250HP Johnston Pump
- #3- Static level 169'4" 300HP BJ Pump

Paragonah East Evans Place:

- #1- Static level 145'3" 125HP Goulds Pump

Parowan Church Farm, North:

- #1- Static level 173'6" 100HP Vertiline Pump
- #2- Static level 155'2" 150HP Johnston Pump

Parowan Church Farm, South:

- #1- Static level 136'6" 75HP BJ Pump
- #2- Static level 130'6" 125HP Layne Pump
- #3- Static level 105'3" 300HP Goulds Pump
- #4- Static level 102' 200HP Layne Pump
- #5- Static level 104'4" 300HP Western Landroller Pump
- #6- Static level 154'8" 75HP BJ Pump

Evens Farm:


- #1- Static level 162'7" 300HP Johnston Pump
- #2- Static level ? Line hangs up at 134' and will go no futher

I certify that these static water level readings were performed by me on 4/12/23 with a Heron water level indicator and are accurate and true.

Darrin Rhodes

Rhodes Pumps II LLC

Fillmore, Utah 84631



1-435-979-0671